



Suncor Energy (U.S.A.) Inc.
 Commerce City Refinery
 5801 Brighton Blvd.
 Commerce City, Colorado 80022
 Tel (303) 286-5701
 Fax (303) 286-5702
 www.suncor.com

CDPHE Malfunction Reporting Form	
Suncor Representative	Craig Neuman
Date of E-Mail Notification	Thursday, December 22, 2022
Time of E-Mail Notification	12:45 PM
Estimated Event Start Date and Time	12/21/22 8:00 PM
Estimated Event End Date and Time	On-Going
Operating Permit No.	95OPAD108 - East Plant & 96OPAD120 - West Plant
AIRS ID No.	073 - Main Plant Flare (F1) 074 - Plant 3 Flare (F2) 025 - #1 Fluid Catalytic Cracking Unit (P103) 279 - Plant 2 Flare (C005) 100 - H-25 TGU Incinerator (H25)
Condition of Permit, Regulation, or Standard Potentially Deviated From (e.g., Condition 25.1)	<p>96OPAD120 - Plant 1 & Plant 3 Operating Permit <u>Condition 29.8</u> - no visible emissions except for periods not to exceed a total of 5 minutes during any 2 consecutive hours <u>Condition 29.9</u> - Plant 1 flare gas shall not exceed 162 ppmv H₂S averaged over a 3-hour period. <u>Condition 30.10</u> - Plant 3 flare gas shall not exceed 162 ppmv H₂S averaged over a 3-hour period. <u>Condition 22.7</u> - opacity not to exceed 20% <u>Condition 20.1</u> - emissions of SO₂ not to exceed 15.68 lbs/hr</p> <p>95OPAD108 - Plant 2 Operating Permit <u>Condition 32.9</u> - Plant 2 flare gas shall not exceed 162 ppmv H₂S averaged over a 3-hour period.</p> <p>EPCRA RQ - 500 lbs SO₂ (24-hour rolling total)</p>
Estimated Maximum Numeric Value of Deviation^a (e.g., ppm, ppmc lb/hr, etc.)	Plant 1 Main Plant Flare H ₂ S - 322 ppmv Plant 2 Flare H ₂ S - 169 ppmv Plant 3 Flare H ₂ S - 191 ppmv #1 FCCU Opacity - 27% H-25 SO ₂ - 27 lbs/hr Total SO ₂ - still under evaluation
Information Regarding Cause of Deviation^b	Event is currently under investigation

Notes:

^aThese are draft emissions estimates and are subject to revisions and/or updates. The final emissions will be reported on the quarterly excess emissions reports.

^bInformation regarding the cause of the deviation may change based on the results of pending investigations. The final deviation cause will be provided in the Malfunction Forms.